

ISO 15848-1

QUALIFICATION

CERTIFICATE



Certificate No.: 317689

Ref. Test report No.: 317690

We hereby certify that the valve below has passed the fugitive emission test successfully according to Class BH of ISO15848-1:2015+Amd.1:2017 for a total of **1500** cycles.

Name of manufacturer	Antiwear (Suzhou) Industrial Intelligent Technology Co., Ltd.
Postal Address of manufacturer	No.988, Yuexiu Road, Fenhua Economic Development Zone, PC: 215200, Suzhou City, Jiangsu Province, P. R. China
Item	1" CL600 Ball Valve
Valve size(NPS)	1"
Pressure rating(Class)	Class600
Stem size	Φ16mm
Body/bonnet material	ASTM A182 F304
Stem seal material	Flexible Graphite Packing
Valve assembly drawing no.	MSBBJ-1C6RJ-X6-D-GW Rev.A1

The tested valve covers performance class (para.6.6):

ISO FE BH – CO2 – SSA0 – tRT – CL600 – ISO 15848-1

Extension of qualification (in particular) to untested valves in accordance with paragraph 8 of ISO15848-1.

Other stem sizes qualified: 8 mm up to 32 mm

Other pressure ranges qualified: Class 600 and lower

This certificate must be read in conjunction with test report No.: 317690

Shanghai, January 22, 2025
(Place, date)

TÜV SÜD Certification and Testing (China) Co., Ltd.
Shanghai Branch
Floor 3-13, No.151, Heng Tong Road,
Shanghai, 200070, P. R. China


Guilin Chen
TÜV SÜD Certification and Testing (China) Co., Ltd.
Floor 3-13, No.151, Heng Tong Road,
Shanghai, 200070, P. R. China

Tel.: +86(0) 21 6141 0123
Fax: +86(0) 21 6140 8600
Internet: www.tuvsud.cn



Test Report

(Valve fugitive emission test according to ISO15848-1: 2015+Amd.1:2017)

Certificate No. : 317689
Test Report No.: 317690

Applicant / Manufacturer: Antiwear (Suzhou) Industrial Intelligent Technology Co., Ltd.
No.988, Yuexiu Road, Fenhu Economic Development Zone,
PC: 215200, Suzhou City, Jiangsu Province, P. R. China

Inspection body: TÜV SÜD Certification and Testing (China) Co., Ltd. Shanghai Branch
Floor 3-13, No.151, Heng Tong Road, Shanghai, P. R. China

Lab of test: Antiwear (Suzhou) Industrial Intelligent Technology Co., Ltd

Test Date: January 17-20, 2025

Description of valves: 1" CL600 Ball Valve
Size:1"
Pressure Rating: Class600
Drawing No. MSBBJ-1C6RJ-X6-D-GW Rev.A1

Test Witnessed By: CHEN Guilin/ TÜV SÜD Inspector

Inspection and Tests

1. Conformity of Equipment

The test equipment was verified by TÜV SÜD inspector according to requirements of ISO15848-1:2015+Amd.1:2017 and found satisfactory. The detailed arrangement of the fugitive emission test equipment is shown below:

Figure 1 Typical stem seal leakage measurement system with Vacuum Method





Figure 2 Typical body seal leakage measurement system with Sniffing Method





Test Report No.: 317690

2. Document review

The specific product data file provided by the valve manufacturer includes:

- a) cross sectional valve assembly drawing;
- b) bill of valve material
- c) stem or shaft seal description, dimension and specifications;
- d) body seal description, dimension and specifications;
- e) material specifications of stem or shaft seal components;
- f) hydrostatic test certificate.

The above documents are reviewed with no objection.

3. Technical Data of Test Valve:

General description of test valve

Name of manufacturer	Antiwear (Suzhou) Industrial Intelligent Technology Co., Ltd.
Postal Address of manufacturer	No.988, Yuexiu Road, Fenhui Economic Development Zone, PC: 215200, Suzhou City, Jiangsu Province, P. R. China
Item	1" CL600 Ball Valve
Valve size(NPS)	1"
Pressure rating(Class)	Class600
Stem size	Φ16mm
Body/bonnet material	ASTM A182 F304
Stem seal material	Flexible Graphite Packing
Valve assembly drawing no.	MSBBJ-1C6RJ-X6-D-GW Rev.A1

4. Visual and dimensional check of the test valve:

The test valve was chosen at random by the manufacturer in its workshop and submitted to the laboratory. The visual and dimensional check was performed according to drawing No.: MSBBJ-1C6RJ-X6-D-GW Rev.A1 and results found satisfactory. The mark was verified on valve as following:

==	1"	600	F304
Manufacturer` Brand	Size	Class	Material

The stem size was measured as Ø16mm.

5. Preparation of the test valve:

Before the fugitive emission test, the test valve was hydrostatic tested under 165bar, the test showed no visible leakage or deformation. Then the valve was cleaned and dried.

6. Calibration of test instrument



Test Report No.: 317690

The test instrument was turned on, warmed up at the minimum time according to the requirements of the equipment manufacturer and calibrated with the standard calibrated leak 100% helium according to the procedure specified in Annex A, Para.A.1.4.2 of ISO15848-1:2015+Amd.1:2017.

7. Fugitive emission test and measurement

The test valve was mounted on a test rig with the stem positioned vertical. And the fugitive emission test is carried out as per requirement of ISO15848-1:2015+Amd.1:2017 Para.5.

7.1 Preliminary tests at room temperature (test 1)

The valve was pressurized with test fluid Helium to 100.0bar according to manufacturer's requirements in the partly opened position, the temperature at locations "X"/"Y"/"Z" are measure and recorded as room temperature

The stem seal leakage measurement was performed by the Vacuum method as described in ISO15848-1 Annex A.

The body seal leakage measurement was performed by the sniffing method as described in ISO15848-1 Annex B.

The test results are as follows:

Test results of preliminary tests

Item	ISO15848-1 Required Value	Actual Value
Stem leakage (mbar.l/s)	$\leq 2.84 \times 10^{-5}$	1.1×10^{-8}
Body seal leakage(ppmv)	≤ 50	10

The test results meet the requirements of ISO15848-1:2015+Amd.1:2017.

7.2 Mechanical cycle test at the room temperature (test 2/3/4/5/6)

A total of 1500 mechanical cycles was performed on the test valve while it was kept pressurized under a differential pressure of 100.0bar according to the manufacturer's requirements at room temperature. The pressure should be improved and kept at 100.0bar to measure the leakage, and then the leakage from the stem seal and from the valve body seal were both measured with following results:

Test results of final tests

Item	ISO15848-1 Required Value	Actual Value
Stem leakage (mbar.l/s)after 50 cycles	$\leq 2.84 \times 10^{-5}$	4.7×10^{-7}
Stem leakage (mbar.l/s)after 100 cycles	$\leq 2.84 \times 10^{-5}$	3.8×10^{-7}
Stem leakage (mbar.l/s)after 150 cycles	$\leq 2.84 \times 10^{-5}$	1.3×10^{-6}
Stem leakage (mbar.l/s)after 200 cycles	$\leq 2.84 \times 10^{-5}$	2.3×10^{-6}
Stem leakage (mbar.l/s)after 205 cycles	$\leq 2.84 \times 10^{-5}$	8.2×10^{-7}
Body seal leakage(ppmv) after 205 cycles	≤ 50	18
Stem leakage (mbar.l/s)after 1000 cycles	$\leq 2.84 \times 10^{-5}$	2.7×10^{-7}
Stem leakage (mbar.l/s)after 1500 cycles	$\leq 2.84 \times 10^{-5}$	1.3×10^{-6}
Body seal leakage(ppmv) after 1500 cycles	≤ 50	12

The test results meet the requirements of ISO15848-1:2015+Amd.1:2017

8. Post test examination

After all the above tests completed, the test valve was disassembled and all sealing components visually examined. It is found that no notable wear and any other significant observations.



Test Report No.: 317690

9. Performance classes

As a result of the above tests, the test valve covered performance classes as follows:

ISO FE BH – CO₂ – SSA0 – tRT – CL600 – ISO 15848-1

10. Extension of qualification to untested valves shall be according to ISO15848-1:2015+Amd.1:2017 paragraph 8.

We, hereby declare that I have checked test valve and witnessed the fugitive emission test on the tested valve according to ISO15848-1:2015+Amd.1:2017. The test results are as mentioned in this report.

TÜV SÜD Certification and Testing (China) Co., Ltd. Shanghai Branch

RONG Zhibin
Prepared by: Rong Zhibin
Chen Guilin
Reviewed by: Chen Guilin

Date: January 22, 2025

Date: January 22, 2025

Annexes:


- 1) Copy of Drawing No.: MSBBJ-1C6RJ-X6-D-GW Rev.A1.
- 2) Test Report of Fugitive Emission Test No. ATW20250101.

Twice & signed

performance specification	
Nominal pressure or pressure level	CLASS 600
Nominal diameter or collar	NPS 1
Shell test pressure (liquid)	16.5MPa
Seat test pressure (gas)	12.1MPa
Seat test pressure (gas)	0.35MPa

- Technical requirements
- 1.Valves are designed and manufactured in accordance with ASME B16.34.
- 2.The structural length of the valve is specified in ASME B16.10.
- 3.The size of the flange connection shall be specified in ASME B16.5.
- 4.The test and inspection of valves shall be in accordance with the provisions of ASME B16.104.
- 5.Pressure temperature rating according to ASME B16.34.

31
30
29
28
27
26
25
24
23
22
21
20
19
18
17
16
15
14
13
12
11
10
9
8
7
6
5
4
3
2
1



TÜV SÜD Certification and Testing (China) Co., Ltd.
Industry Service

☒ reviewed

☐ witnessed

by Don Goulin
dated 2025-1-17

受控

31	Bolt-G8/T5783-M6x10-8.8+Zn	1	A1	
30	Washer-G8/T5287-6-A2	1	A1	
29	Locating plate-14x11x2x25-304	1	A1	
28	Check ring-G8/T894.1-14-A2	1	A1	
27	Wrench-11x250-QF8	1	A1	
26	Standard disc spring-G8/T1972-A16-631	2	A1	
25	Screw-G8/T70.1-M6x30-B8-2	2	A1	
24	Packing bushing-16.5x28x15-X6-304	1	A1	
23	Hold-down grid-18x46x10-X6-QF8	1	A1	
22	Packing seat-16x24x2-316	1	A1	
21	Packing-16x24x4-Flexible graphite	2	A1	
20	Graphite annulus-16x24x4-Flexible graphite	2	A1	
19	Nut-G8/T6175-M8-A194-8	4	A1	
18	Fully threaded stud-G8/T801-M8x30-B8-2	4	A1	
17	Self-G8/T118.1-8x20-A2	2	A1	
16	Gland box-106Y-C-T76-X6-F316L	1	A1	
15	Graphite annulus-28x36x4-Flexible graphite	1	A1	
14	Coil bearing-16x18x10-SD-X6-316L+QPQ	1	A1	
13	Coil bearing-25x28x15-SD-X6-316L+QPQ	1	A1	
12	Thrust bearing-17x24.5x2-SD-X6-316+QPQ	2	A1	
11	Valve stem-B11x16x81x145-0.8-PT-X6-F316L-19+G14	1	A1	
10	Sphere-106Y-Q25-X6-B-F316L+G14	1	A1	
9	Junk ring-34x40x4.6-X6-316	2	A1	
8	Seat ring-34x40x5-J45-Flexible graphite	2	A1	
7	Valve seat-106Y-PHB-YF-Q25-X6-D-F316L+G06	2	A1	
6	Disc spring-39.5x28.5x1.2x2.1-X6-Inconel750	2	A1	
5	Graphite annulus-53x61x4-Flexible graphite	1	A1	
4	Nut-G8/T6175-M14-A194-8	4	A1	
3	Fully threaded stud-G8/T801-M14x50-B8-2	4	A1	
2	Bonnet-106RJ-Q25-X6-D-GW-F304	1	A1	
1	Valve body-106RJ-L-Q25-X6-D-GW-F304	1	A1	
NO	Specification	Number	Version	Remark

ATIV
Suzhou Industrial Intelligent
Technology Co., Ltd.

Serial number	Change file number	Signature	Date
Design	Yi Peng	Hao Liangjun	A1
Audit	Yang Shujun		
Approval	Li Yufei	2021/2/18	1:2.5



MSB8J-106RJ-X6-D-GW

受控

Approval	LI Yufei	Date	2025/1/20	Proportion	1:1
Audit	Yang Shujun	Substance	0.25kg	Specification	Valve stem-B11x16xB12x145-0.8-PT-X6
Design	Wang Ruipeng	Proofread	Dong Wei	Edition	A3
Serial number	Change file number	Signature	Date	Suzhou Antway Industrial Intelligent Technology Co.,LTD	

1. The materials meet the requirements of Suzhou Industrial Intelligent Technology Co., Ltd.
2. Spraying cemented carbide, coating hardness HRC $\geq$ 60, coating surface shall not have cracks, outside the spraying surface should be well protected during the spraying process, the effect shows the final molding size;
3. Class B size 4 pieces;
4. The processing surface is sharpened and blunt, and burrs are removed;
5. The limit deviation of the processing size without tolerance is stipulated by GB/T11804-2013;
6. The limit deviation of the processing size without tolerance is stipulated by GB/T11818-K.

Technical requirements



View C

6H - 9M
Wire depth 8 hole depth 10

H9 - 9W

The rest

$$\begin{array}{r} \triangle \\ 3.2 \end{array}$$

苏州安特威工业智能科技股份有限公司

ISO15848-1型式试验阀门低泄漏试压记录表

阀种		规格	试验日期	报告编号	中道壳体检漏值
序号	项目	试验温度	试验内容	壳体外漏要求值	中道壳体检漏值
1	球阀	常温	从入口通入10MPa氦气, 检测阀杆填料和壳体中道外漏, 氦气漏率满足要求值	50ppm	10 ppm
2		常温	从入口通入10MPa氦气, 阀门动作开关 50 次后, 检测阀杆填料外漏, 氦气漏率满足要求值	/	/
3		常温	从入口通入10MPa氦气, 阀门动作开关 50 次后, 检测阀杆填料外漏, 氦气漏率满足要求值	/	/
4		常温	从入口通入10MPa氦气, 阀门动作开关 50 次后, 检测阀杆填料外漏, 氦气漏率满足要求值	/	/
5	低压漏测试	常温	从入口通入10MPa氦气, 阀门动作开关 50 次后, 检测阀杆填料外漏, 氦气漏率满足要求值	/	/
6		常温	从入口通入10MPa氦气, 阀门动作开关 5 次后, 检测阀杆填料和壳体中道外漏, 氦气漏率满足要求值	50ppm	18 ppm
7		常温	从入口通入10MPa氦气, 阀门动作开关 795 次后, 检测阀杆填料外漏, 氦气漏率满足要求值	/	/
8		常温	从入口通入10MPa氦气, 阀门动作开关 500 次后, 检测阀杆填料和壳体中道外漏, 氦气漏率满足要求值	50ppm	12 ppm
执行标准 ISO 15848-1					
试压		日期	7.25.1.20		

10v50 Certification and Testing (China) Co., Ltd.
Industry Service

☐ reviewed

☒ witnessed

by Chen
dated 2025.1.20